

From Assistant Divisional Fire Officer/Fire Station Officer
Fire Station Sec 15A

823

To M/s Dronacharya Public School
SECTOR 56 SAMAYPUR SOHNA ROAD VILLAGE KABOOLPUR FARIDABAD

Memo No. FS/2023/632 dated : 05/10/2023

Subject: Renewal of Fire Safety Certificate Under 15 mtrs. height from the fire Safety Point in view of the Group B-Educational Building at SECTOR 56 SAMAYPUR SOHNA ROAD VILLAGE KABOOLPUR FARIDABAD of Dronacharya Public School :

Reference to you online No 030162323000342 dated 16/09/2023 on the subject cited above.

Tower Name	Floor Detail	Height	Ground Coverage
Educational Building	Ground	4	2000 Sqft
Basement Level	Basement Area	Remarks	
NIL	NIL	NIL	

View site for the Renewal of the Fire Safety Certificate has been inspected by the Team of Fire Station Officers, Fire Station Sec 15A from fire safety Point of View. The means of escape and Fire Protection system were checked and found as per the National Building Code of India, Part- IV guidelines.

In view of the satisfactory fire protection system / arrangement mentioned as above, this office has no objection for occupation from the Fire Safety point of view, with the following conditions:-

- 1) The owner/occupier shall keep duly trained Fire Staff in all time.
- 2) The Fire Protection System tested during inspection is to be kept in good & working condition.
- 3) If any lapse is found in the fire protection system at the time of any fire, action will be taken as per rules against you.
- 4) You are directed to apply for Renewal of Fire Safety Certificate in time before 2 months of expiry of your Fire Safety Certificate.
- 5) The open set back area is not checked at our end as it shall be checked by competent authority.
- 6) The owner/occupier shall strictly follow the other applicable rules/regulations by the Govt regarding fire safety system. If you fail to comply with any of the above terms & conditions, you shall be liable as per Section 30,31 & 47 of fire & Emergency Services Act 2022.
- 7) You have to perform quarterly Fire Drill in your building as per NBC with intimation to Fire Department and video graphy evidence to be kept as a record which shall be produced at the time of next Renewal, Officer in Residence R.W.A. should be mentioned in the drill.
- 8) If the Infringements of Byelaws remains un-noticed the Authority reserves the right to amend the Fire Safety Certificate as and when any such Infringements comes to notice after giving an opportunity of being heard and the Authority shall stand indemnified against any claims on this account.
- 9) The owner or occupier of the building shall give a self-declaration certificate annually to the effect that the fire fighting system installed in his building is working in good condition and there is no additional work done on the building. The Fire Officer may randomly check such building. In case there is any addition/alteration beyond permissible limits under the Haryana Building Code, 2017, the fire safety certificate shall cease to exist and the owner shall apply for approval of revised Fire Fighting Scheme as per the provisions of section 18.

The above Renewal of Fire Safety Certificate is valid for **Three** year from the date of issue of this letter. Applying renewal of the same well in time shall be the responsibility of owner/occupier.

Remarks:- ok



Assistant Divisional Fire
Officer



Digitally signed by Sanyam
Walter Sec 15A, 12/10/23

Exercising

10030
Haryana Fire Services 2000