

**PUBLIC HEALTH ENGINEERING DEPARTMENT**

DISTRICT WATER TESTING LABORATORY, FARIDABAD

Website :- <https://phedharyana.gov.in/>

Memo No:- 701

Date:- 27/6/2023

Subject: **Bacteriological Examination Report of Water Sample**

Sample ID:	FBD/00447/6/2023	Sample Details	Date & Time
Sample Classification:	Private	Collected By	9811020568
Sender:	Dronacharya Public School/22479	Collection Date	21/06/2023 at 15:19
Location :-	: Sector-56, Samaypur, Sohna Road, Village Kaboolpu	Received at lab	21/06/2023 at 16:04
Latitude :-	77.294588	Tested at Lab	27/06/2023
Longitude :-	28.326919		


Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/ APHA 9221C; 2017

Remarks :-

- * The Results Given above are related to the sample as received and tested in FARIDABAD Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters.
Based on the tested parameters, the water sample is found "POTABLE"



Vandana
VANDANA DESWAL, CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING
LABORATORY, FARIDABAD
email: chemist.fad@phedharyana.gov.in

—End of Report—